FIRE SAFETY SELF-AUDIT

My home

Pune, Maharashtra · Home · 1 floor · 1,000–2,000 sq ft · 3–5 people



64
out of 100

Needs attention

2	3	16	3
Fix now	Fix soon	Safe	Not checked

Who checked

The owner, with the AGNIYA app, guided by its voice and camera, on 28 Oct 2026. One finding was confirmed by an AGNIYA expert before this report was made.

A self-audit tool. Not a substitute for a statutory Fire NOC. It covers what can be seen and answered on the day.

Your score by area

AREA	SCORE	RESULT
Detection	40	! Fix now
Suppression	86	✓ Safe
Egress	48	! Fix now
Electrical	62	Fix soon
Housekeeping	70	Fix soon
Compliance	78	✓ Safe

What to fix first

1 ! Fix now **No smoke alarm in the kitchen**
Fit an alarm on the ceiling, a little away from the stove.

2 ! Fix now **Main door blocked by a shoe rack**
Move the rack so the door opens all the way.

3 Fix soon **Gas hose close to the burner**
Route the hose away from the flame; replace it if worn.

4 Fix soon **Extension board overloaded**
Spread the plugs over more sockets, and unplug heaters when not in use.

5 Fix soon **Emergency numbers not on display**
Put the fire, ambulance and gas emergency numbers near the main door.

How to read this report

Areas are Safe (75 and above), Fix soon (50 to 74) or Fix now (below 50). The overall score uses the same bands, named Good, Needs attention and At risk. Not checked items aren't counted.

Findings



! Fix now Detection · D-02

No smoke alarm in the kitchen

What we saw: no smoke alarm on the kitchen ceiling or nearby.

Why it matters: a kitchen fire can spread before anyone notices.

How to fix it: fit an alarm on the ceiling, a little away from the stove.

Seen by the camera · Model checkpoint-model 0.3 · Confidence 91%

! Fix now Egress · E-01

Main door blocked by a shoe rack

What we saw: a shoe rack stops the main door from opening fully.

Why it matters: in smoke, every second at the door counts.

How to fix it: move the rack so the door opens all the way.

Seen by the camera · Model checkpoint-model 0.3 · Confidence 91%



Fix soon Housekeeping · H-03

Gas hose close to the burner

What we saw: the hose from the cylinder runs right beside the burner.

Why it matters: heat can crack the hose over time and let gas leak.

How to fix it: route the hose away from the flame; replace it if worn.

Seen by the camera · Model checkpoint-model 0.3 · Confidence 91%

The other 2 findings are listed with all 24 checkpoints on the next page. Photos are from the owner's safety check.

All 24 checkpoints

CODE	CHECKPOINT	RESULT	HOW IT WAS CHECKED
D-01	Smoke alarm in the living area	✓ Safe	Camera
D-02	Smoke alarm in the kitchen	! Fix now	Camera
D-03	Building fire alarm works	– Not checked	Skipped by the owner
S-01	Extinguisher in the home	✓ Safe	Camera
S-02	Extinguisher within reach of the kitchen	✓ Safe	Camera
S-03	Extinguisher pressure gauge in range	✓ Safe	AGNIYA expert
S-04	Extinguisher service date	✓ Safe	Camera (service label)
E-01	Main door opens fully	! Fix now	Camera
E-02	A second way out	✓ Safe	Confirmed by the owner
E-03	Keys for locked doors within reach	✓ Safe	Confirmed by the owner
E-04	Corridor and stairs clear	✓ Safe	Camera
E-05	Terrace door	– Not checked	Skipped by the owner
L-01	Main switch within reach	✓ Safe	Camera
L-02	Extension boards not overloaded	Fix soon	Camera
L-03	No exposed wiring joints	✓ Safe	Camera
L-04	Circuit breaker panel labelled	✓ Safe	Camera
L-05	Electricity meter box	– Not checked	Skipped: locked
H-01	LPG cylinder upright and ventilated	✓ Safe	Camera
H-02	Regulator turned off at night	✓ Safe	Confirmed by the owner
H-03	Gas hose clear of the burner	Fix soon	Camera
H-04	Nothing that burns near heat sources	✓ Safe	Camera
C-01	Emergency numbers on display	Fix soon	Confirmed by the owner
C-02	Everyone at home knows the way out	✓ Safe	Confirmed by the owner
C-03	Building's fire safety contact known	✓ Safe	Confirmed by the owner

Every checkpoint is mapped to NBC 2016 Part 4; the clause for each is in the app. Codes and clauses come from AGNIYA's checkpoint catalogue.